


Identifying Energy Efficiency Strategies for Laboratories

LABS 21

NREL, Otto Van Geet

Enermodal Engineering, Sue Reilly

Building Model



- 100,000 net sf
- CAV w/ hot water reheat
- 74F/72F w/ Min 30% RH, Max 60% RH
- Chillers: 0.5 kW/ton
- Boilers: 80% η
- Electricity: \$0.03/kWh, \$7/kW
- Gas: \$0.6/therm

Climates

	Minneapolis	Denver	Seattle	Atlanta
Winter design temperature (F)	-11	3	28	23
Summer design temperature (F)	88/77	90/59	81/64	91/74
HDD65 (F-days)	8002	6113	4867	3089
CDD65 (F-days)	634	566	127	1611

Internal Loads

Plug Loads

- Perimeter-10 W/sf
- Core – 8.52 W/sf

Lighting

- Perimeter-1.8 W/sf
- Core – 1.4 W/sf


People

•275 sf/per


8am-10pm, M-F

All Loads Scheduled

Effect of Plug Load Assumption



How Much Air?



Outside Air Requirements

Fume Hoods


- 1 hood/450 sf
- 18" high, 6' wide
- 100 fpm face velocity
- Average exhaust = 900 cfm or 2cfm/sf




Design Air Flow (cfm/sf)

	Base	Plug 6 W/sf	Plug 3 W/sf
Minneapolis	2.1	2.0	2.0
Denver	2.5	2.1	2.0
Seattle	2.1	2.0	2.0
Atlanta	2.1	2.0	2.0


Fan Energy Use




Base Case



Heating and Humidity Control



Different Levels of Humidity Control



Efficiency Strategies


Ventilation

- VAV
- Flow Setback
- Low pressure drop


Energy Recovery

- Enthalpy Wheel
- Heat Pipe
- Run-Around Loop
- Condenser Water


VAV and Flow Setback



Annual Energy Costs




Total Energy Use




Energy Recovery Ventilation

Space Cooling and Fan Electricity Savings




ERV Energy Costs




Downsize Chilled Water System

Reduction in Chiller Tonnage



Downsize Hot Water System



Conclusion

Present Value, \$/sf

	Minneapolis	Denver	Seattle	Atlanta
VAV	\$5.4	\$1.2	\$2.5	\$4.0
Wheel	\$18.3	\$10.5	\$3.4	\$5.6
Adv Wheel	\$22.4	\$11.9	\$4.5	\$10.0
Adv Loop	\$15.5	\$7.0	\$4.3	\$7.5